

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7315-1490:100 Page 1 of 1

**CATEGORY:** Power Units

**LISTEE:** Paradox Security Systems, 780 Industriel Blvd., St-Eustache, Canada J7R 5V3  
Contact: \*Marc Bertrand (450) 491-7444

**DESIGN:** Model PARADOX-POWER 12 ADT power supply/battery charger. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation, electrical rating and UL label.

**APPROVAL:** Listed as a power supply/battery charger for use with separately listed compatible fire alarm control units to provide auxiliary power.

**NOTE:** 7315-1437:100\*

\*Rev. 06-18-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager